



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 28	bc stopping in ZSS, control wire loose in module	tightened	11:45:00	11:59:00	
2	CHP	cc 51	mpd tripped 5 times	reser	11:00:00	11:05:00	
3	CHP	CC 58	olr atced	reset	07:30:00	07:45:00	
4	CHP	CC 131	olr acted	reset	10:35:00	10:40:00	
5	CHP	CC 33 STKR3	slew left not working,limit acted	limit bypassed than ok,kept back in ckt	07:20:00	07:40:00	
6	CHP	CC 37 SCR3	luff not working,oil level low	informed mech	07:15:00	07:25:00	
7	CHP	CC 223	mccb tripped	made on	08:45:00	08:55:00	
8	CHP	CC 203	olr acted	reset	10:45:00	10:55:00	