



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/08/2025

Area: WT

Equipment	Job
OT 5	LS 1 and 2 Limits cables removed due to Tippler breakdown and 'HIGH' wire removed.
OT 4	Hopper area lighting distributed and 2*400W SV fitting installed , control JB provided
OP 4	D2 motor removed for mechanical job
OP 1,4 and 7	After rake maintenance done