



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/09/2025

Area: CHP

Equipment	Job
CC 109/110	Gallery lighting ckt problem rectified and improved lighting
CC 201 Belt scale	4 sensors canopy provided
SCR 7	LT motor-2 placed on the bed,aligned and termination done
CM 18, Coal complex	Rooms cleaning was done
Repair shop	2 nos tube fixtures and one 50W lamp replaced