



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/11/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-22	Reported fire observed from cable and machine having no power	Checked and found one HT fuse open and old joint open and cable burnt. Fresh joint made by DNW and HT fuse replaced and operations tested okay	22:50:00	03:15:00	
2	OHP	CO-25	Reported tripped	OLR acted.Reset done	22:40:00	22:50:00	
3	OHP	CO-26	Reported tripped	Fuse burnt in CJB.Fuse replaced and tested okay	22:45:00	22:55:00	
4	OHP	BRC ON CO-33M	Reported LT not taking place	PCRD OT acted.Released and tested okay	23:50:00	00:05:00	Informed mechanical to adjust guide
5	OHP	CO-26	Reported tripped	OLR acted.Reset done	04:25:00	04:30:00	
6	CHP	CC 39 SCR-2	Reported LT not taking place	PCRD OT acted.Released and tested okay	00:31:00	00:40:00	
7	CHP	CC-51	Reported Tripped	MPD tripped(5 times).Reset done	03:30:00	05:45:00	
8	CHP	CC-58 TT	Reported no movement	LT motor MPCB tripped.Made on.	22:15:00	22:35:00	
9	CHP	CC39 SCR-2	Reported LT not working	PCRD MPCB tripped.Made on	01:22:00	01:40:00	