



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED	RESET DONE	13:35:00	13:44:00	
2	OHP	WOBR ON CO 29	It NOT TAKING PLACE,M3 TRIPPED	RESET	13:18:00	13:25:00	
3	OHP	brc ON CO 32	MPR TRIPPED DUE TO jamming	reset	10:15:00	10:25:00	
4	OHP	CO 26	olr acted	reset	08:05:00	08:10:00	4 times
5	CHP	cc-51	MPD TRIPPED	RESET DONE	09:35:00	09:40:00	
6	CHP	CC-52	MPD TRIPPED	RESET DONE (6 TIMES)	11:00:00	14:00:00	
7	CHP	CC-114	OLR ACTED	RESET DONE	09:40:00	09:45:00	
8	CHP	CC 104 scr 9	luff not working,common high fuse in i/o rack panel blown	fuse replaced	08:00:00	08:45:00	
9	CHP	SCR 9 cc 104	It not working,m3 and m5 tripped	reset	08:00:00	09:00:00	
10	CHP	CC 45	olr acted	reset	07:45:00	07:55:00	
11	CHP	CC 37 SCR 7	b/c not running,cjs acted	informed operation	08:15:00	08:30:00	
12	CHP	CC 109	olr acted	reset	07:20:00	07:25:00	
13	WT	OC 1A	tripped on olr	reset	11:20:00	12:00:00	3 times