



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/08/2025

Incharge(s): V Balaji Naik

Shift: A

| Sl No | Area | Equipment        | Problem                                                          | Action               | From     | To       | Remarks                                                       |
|-------|------|------------------|------------------------------------------------------------------|----------------------|----------|----------|---------------------------------------------------------------|
| 1     | OHP  | CO7              | BRS bypassed was removed on operational request                  | Kept in ckt          | 06:15:00 | 06:15:00 |                                                               |
| 2     | OHP  | RSCO10A carriage | MPCB Tripped                                                     | Reset done           | 12:00:00 | 12:10:00 |                                                               |
| 3     | OHP  | CO19             | BRS not getting reset found trans and receiver alignment problem | Reset done           | 13:27:00 | 13:45:00 |                                                               |
| 4     | OHP  | CO25             | olr acted                                                        | Reset done           | 11:00:00 | 11:10:00 |                                                               |
| 5     | OHP  | CC125            | OLR tripped 2 times                                              | Reset done           | 08:20:00 | 08:25:00 | 01.20am to 01.25am                                            |
| 6     | CHP  | CC51             | Tripped and feeding conveyor stopped 4 times                     | Reset done           | 06:40:00 | 06:45:00 | 08.30am to 08.35am :<br>09.50am to 09.55am:01.05pm to 01.10pm |
| 7     | CHP  | CC54             | Olr tripped due to over load                                     | Reset done           | 12:55:00 | 13:00:00 |                                                               |
| 8     | CHP  | CC33             | BRS bypassed as per operational request                          | bypassed             | 12:30:00 | 12:40:00 |                                                               |
| 9     | CHP  | SCR4 on CC33     | LT not working found VFD drive tripped (SCF-3)                   | Reset done then ok   | 13:15:00 | 13:25:00 |                                                               |
| 10    | CHP  | CC47             | Not started                                                      | Power recycling done | 07:15:00 | 07:18:00 |                                                               |
| 11    | WT   | OT2              | Drive 1 tripped on PGF fault                                     | Reset done           | 08:30:00 | 08:35:00 |                                                               |
| 12    | WT   | OT4              | Drive1 tripped on PGF fault                                      | reset done           | 10:00:00 | 10:05:00 |                                                               |