



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/09/2025

Shift: A

Incharge(s): V Balaji Naik,Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO25	olr acted	reset	08:50:00	08:55:00	
2	OHP	CO 29	olr acted	reset	09:15:00	09:25:00	
3	OHP	CO 26	olr acted	reset	09:55:00	10:00:00	two times
4	OHP	CR 1	tripped due to over current.material jamming	reset	08:05:00	08:10:00	
5	OHP	CO 61	olr acted	reset	12:50:00	12:55:00	
6	OHP	CO 34 BRC	LT not taking place,skew limit acted,mains off by operator	mains on,and skew bypassed and than put in ckt	10:30:00	11:00:00	mechanical and operation problem
7	CHP	CC 39 SCR 7	slew not working	wrong complaint	07:50:00	08:00:00	
8	CHP	Cc 40 SCR3	LT not working,drive trips in overload	reset	10:30:00	10:40:00	
9	CHP	CC 31 SCR 4	luffing not taking place,luff limit acted	limit released	13:05:00	13:15:00	
10	CHP	CC 39 SCR 7	Lt not taking place,drive trips in ol	reset	13:15:00	13:25:00	
11	CHP	CC 25	healthy stops,TT position on 34 not properly	TT position done properly on 34	09:44:00	10:00:00	
12	CHP	CC-51	Feeding conveyor stopped	Due to olr.Reset done	07:10:00	07:15:00	