



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/02/2026

Area: OHP

Equipment	Job
locp-2 crusher auxillaries	solenoid plugs cleaning was done and replaced worn out ones.
co-5	motor and panel side ppm is done.
Crusher-2	Ht fuse replaced in cr-2 panel and 2 spares kept at lc-7
IO-7	HT io panel maintenance is done.
tbs-3 on co-20	Right Boom mccb is replaced, trail run is taken.