



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/08/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 16	tripped in olr	reset	12:40:00	12:45:00	
2	OHP	CO 4A	reported red,pull chord operated	pc released	07:30:00	07:40:00	
3	OHP	CO 29	OLR acted	reset	08:20:00	08:30:00	
4	OHP	CR 1	not healthy,mpr acted	reset	08:00:00	08:05:00	
5	OHP	TBS on CO 23	LT not taking place,track full jammed with flux	informed operation	07:00:00	07:15:00	
6	OHP	CO 35	OLr acted	reset	12:00:00	12:05:00	
7	CHP	CC 33	mpr trips due to olr	reset	08:05:00	08:10:00	3 times
8	CHP	CC 33 scr 4	b/ c stops in zss,,zss bypassed have loose connection	tightened	08:20:00	08:25:00	
9	CHP	CC 35 SCR 1	LT not working,track jammed	informed operation	08:20:00	08:30:00	
10	CHP	CC 36 S2	LT not working,pcrd cable fallen	pcrd cable winding	09:00:00	09:15:00	
11	CHP	CC 36 S2	slew not taking place,slew limit acted	limit released	09:00:00	09:15:00	
12	CHP	CC 47	zss not healthy,proximity sensor not properly adjusted	sensor adjusted	10:00:00	10:10:00	
13	CHP	cc 51	mpd trips due to feeding conveyor olr	reset	07:00:00	07:20:00	5 times
14	CHP	CC 54	tripped in olr	reset	09:20:00	09:25:00	
15	IOSA	new wobr	LT not taking place, brake mpcb trips	made it on	13:20:00	13:40:00	