



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/05/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 5	BRS to be bypassed as per operation request	Bypass done at CJB	22:15:00	22:30:00	
2	OHP	CO 35	OLR acted	reset done	04:30:00	04:40:00	
3	OHP	TBS on CO 5A	LT not stopping reported	Checked , LT stopping	01:00:00	01:20:00	
4	OHP	BRC on CO 32	BW 2 not rotating due to OLR acted	reset done	00:50:00	01:10:00	
5	OHP	TBS on CO 20	LT forward and reverse done	Mechanical requirement	00:00:00	01:30:00	
6	OHP	CO 87	OLR acted	reset done	23:00:00	23:15:00	
7	OHP	RSCO 10A	MCCB tripping frequently	Checking going on	04:30:00	06:00:00	
8	OHP	RSCO 6A	OLR acted	reset done	05:30:00	05:40:00	
9	OHP	CO 26	OLR acted	reset done	05:45:00	05:50:00	
10	CHP	CC 222	Not healthy , drive tripped	reset done	00:20:00	00:40:00	
11	CHP	CC 105 , SCR 10	Slew and BW not healthy	In operator cabin push button made ON	02:30:00	03:10:00	
12	CHP	CC 33 , SCR 4	BC not running due to OLR acted	reset done	03:35:00	04:00:00	
13	CHP	CC 39, SCR 7	LT not working	Found in PCRD gearbox chain got open , informed to mechanical	04:45:00	05:00:00	
14	CHP	CC 33 , SCR 4	Slew not working	Material jamming near limit switch area, informed operation for cleaning	05:00:00	05:20:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/05/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC 131	Tripped on overload ( 3 times)	reset done	01:15:00	04:40:00	From 6.50 pm to 9.35 pm tripped ( 4 times)
16	CHP	CC 54	Motor tripped on overload ( 5 times)	reset done	00:10:00	04:45:00	
17	CHP	CC 32	BRS to be bypassed , operation request	BRS bypassed	05:20:00	05:23:00	In system
18	WT	OT 4	Drive 2 tripped on pgf 4 fault	reset done	00:30:00	00:35:00	