



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 24/11/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	CT END LIMIT ACTUATOR WELDING WORK DONE. CT OPERATIONAL END LIMIT SWITCH BASE GOT DAMAGED. RECTIFICATION IN PROGRESS.
MANUAL UN-LOADING YARD	LIGHTING DEFECTS RECTIFIED AND PROVIDED TWO 200W LED LAMPS
OC-7B	CABLE FOR HOT JOINT , SHIFTED TO OC-7B CONVEYOR GALLERY. ADDITIONAL LIGHTING PROVIDED
OC-7B	CONTROL CABLE AT HT PANEL GOT DAMAGED NEAR GLAND. RECTIFIED AND INSULATED.
OC-7B	MAINTENANCE DONE ON HT BREAKER . CHECKED THE BREAKER OPERATION.
OC-21A	MAINTENANCE DONE ON HT BREAKER
OC-5A	LIGHTING DEFECTS RECTIFIED AND LIGHTING IMPROVED.
OC-19A	PPM DONE ON FIELD DEVICES