



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/11/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.reset done	04:30:00 05:00:00 22:40:00 23:50:00	04:35:00 05:10:00 22:50:00 00:00:00	
2	OHP	BRC on CO-33M	Lt not taking place	PCRD limit acted.Released and tested okay.Mechanical guide problem	00:35:00	00:50:00	Informed to mechanical for guide adjustment
3	OHP	CO-77	Reported tripped	OLR acted.Reset done	03:15:00	03:20:00	
4	OHP	CC-51A	ZSS acted	Stone stuck up.Removed and tested okay	04:50:00	05:10:00	
5	OHP	OT-1	Drive tripped	D1 tripped twice on PGEF fault.Reset done	03:05:00	03:10:00	
6	OHP	OC-1A	Belt drive tripped	OLR acted.Reset done.	05:30:00	05:35:00	
7	CHP	CC114	Reported tripped	OLR acted.Reset done(2times)	04:10:00 23:45:00	04:15:00 23:50:00	
8	CHP	cc54	Reported tripped	OLR acted.Reset done	01:40:00 03:50:00	01:45:00 03:55:00	
9	CHP	Cc51	Reported tripped	MPD acted.Reset done(2 times)	03:55:00 04:15:00	04:00:00 04:20:00	
10	CHP	Cc-103	Reported healthy stop	Checked and tested okay	23:40:00	23:50:00	
11	CHP	CC103 on 105	Position not coming	Sensor was bypassed	04:30:00	04:45:00	
12	CHP	Cc-35 SCR-3	Slew not working	Slew chamber jamming found.	23:00:00	23:20:00	Informed to operation



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/11/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-35 SCR3	BC not running	ZSS cage stuck.Made free	00:19:00	00:30:00	
14	CHP	Cc-42	CJD acted	Jamming found	01:40:00	02:00:00	Informed to operation
15	CHP	Cc105 SCr-10	BC not running	MPR acted.Reset done	05:14:00	05:23:00	
16	CHP	cc35	Reported tripped	OLR acted.Reset done	05:35:00	05:40:00	
17	WT	CP-3	Pusher crossed cut off section	Pusher pushed with loco and power collectors are placed	03:30:00	05:00:00	