



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO8A	B/W S NOT RUNNING ZS PROBLEM	B/W 1 B/W 2 ZSS BYPASSED	00:10:00	00:40:00	DUE TO FESTOON CABLE PROBLEM
2	OHP	WOBR ON CO 26	B/C STOPPING ON ZS CAGE STUCK UP WITH STONE	REMOVED	02:20:00	02:40:00	
3	OHP	CO 29	OLR ACTED (3TIMES)	RESET	03:05:00	04:05:00	
4	OHP	BRC ON CO33M	B/W S NOT RUNNING	NO ELECTRICAL PROBLEM	02:30:00	02:40:00	
5	CHP	CC 54	OLR ACTED(3TIMES)	RESET	22:35:00	03:15:00	
6	CHP	CC 117	OLR ACTED(2TIMES)	RESET	00:35:00	05:25:00	
7	CHP	CC 39 SCR 7	slew and B/W not running, return oil filter problem	return oil filter bypass as per operation and mechanical	04:10:00	04:25:00	mechanical will changed in A SHIFT
8	CHP	CC 131	OLR ACTED	RESET	01:10:00	01:15:00	
9	CHP	cc 41	motor not running, CJS acted due to jamming	informed operation	04:10:00	04:20:00	
10	WT	OP 9	no movement, communication problem, signal strength bad 95db	pusher moved in local than ok	01:50:00	02:15:00	
11	WT	OC1A	OLR ACTED	RESET	04:45:00	05:00:00	DUE TO MATERIAL JAMMING