



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/02/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC-40 SCR-2	SLEW NOT WORKING DRIVE TRIP	RESET DONE THAN OK	07:20:00	07:35:00	
2	CHP	CC-34 SCR-7	REPORTED LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED THAN OK	08:40:00	09:00:00	
3	CHP	CC-58	OLR ACTED (4TIMES)	RESET DONE	08:45:00	09:15:00	
4	WT	OP-5	DRIVE-1 OLR ACTED	RESET DONE	06:25:00	06:35:00	