



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/08/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-61(B/D)	Reported tripped	Olr acted.Reset done	01:19:00	01:35:00	
2	OHP	WOBR on CO-26	Reported slewing not taking place	Drive tripped.Reset done	23:10:00	23:25:00	
3	OHP	CO-29	Reported tripped	OLR acted.Reset done(4 times)	01:20:00 03:10:00 04:15:00 23:15:00	01:25:00 03:15:00 04:20:00 23:20:00	
4	OHP	CO-26	Reported tripped	OLR acted.Reset done	01:05:00	01:15:00	
5	OHP	CO-34	Reported tripped	OLR acted.Reset done	01:35:00	01:40:00	
6	OHP	CO-84	Reported tripped	OLR acted.Reset done	02:10:00	02:20:00	
7	CHP	CC-54	Reported tripped	OLR acted.Reset done(4Times)	00:30:00 00:40:00 00:55:00 05:30:00	00:35:00 00:45:00 01:00:00 05:35:00	
8	CHP	CC-51	Reported tripped	OLR acted.Reset done(4times)	00:55:00 02:10:00 05:05:00 05:20:00	01:00:00 02:15:00 05:10:00 05:25:00	
9	CHP	CC-114	Reported tripped	OLR acted.Reset done	02:00:00	02:05:00	
10	CHP	CC-44	Reported tripped	OLR acted(7 times) due to belt overload.Kept in local and material cleared and kept in plc and tested okay	23:19:00	23:45:00	
11	CHP	CC-38 SCR-6	B/C not working	Signal missing.LT done and tested okay	00:13:00	00:18:00	



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 30/08/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-36 SCR-1	Reported signal missing	LT done and tested okay	00:27:00	00:30:00	
13	CHP	CC-39 SCR-7	B/C not moving	BC discharge chute jamming.	01:23:00 03:20:00	02:15:00 03:30:00	Informed to operation and cleaning done and tested okay
14	CHP	CC-44	Reported tripped	olr acted.Reset done	01:40:00	02:00:00	
15	CHP	CC-104	ZSS not working	Cable cut.Rejoint done and tested okay.Still conveyor not rotating.Mechanical problem	04:30:00	04:50:00	Informed to mechanical
16	CHP	CC-105	Reported conveyor not moving	No electrical problem.Mechanical pulley not rotating	05:35:00	05:45:00	Informed to mechanical
17	WT	OT-4	Hydraulic pump not working	Emergency stop acted.Released and tested okay(No delay)	23:30:00	23:35:00	