



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/11/2025

Area: OHP

Equipment	Job
CO-64, CO-62	CJD are installed and programmed such that conveyor stops when respective direction cjd acts and indication provided in OCR HMI
rco-1a and rco-2a chute sensors	cjd's are programmed as to stop then conveyor when its respective directions cjd is acted. and indication provided in ocr hmi.