



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 24/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO51	not healthy found control glass fuse blown out at motor JB	Fuse replaced then ok	23:49:00	23:59:00	
2	OHP	CO57	Pull card not healthy found control MCB side loose	Tightened control cable then ok	00:30:00	00:48:00	
3	OHP	CO35	OLR acted	Reset done	00:10:00	00:19:00	
4	OHP	CO29	OLr acted	Reset done	01:30:00	01:35:00	
5	OHP	BRcon CO28	BC not healthy found electronic olr acted	Reset done	04:40:00	05:00:00	
6	OHP	RSCO9a	Electronic olr acted	Reset done	00:00:00	00:10:00	
7	OHP	CO11 carriage	MPCB tripped due to track jaming	MPCB made on	01:45:00	01:55:00	
8	CHP	cc-37	BRS frquently acting	checked and found no problem. bypassed and kept under observation	22:30:00	22:45:00	kept in circuit
9	CHP	SCR-6 on cc-38	slew not working	90 deg limit acted. released	23:15:00	23:30:00	
10	CHP	scr-4 on cc-31	slew not working	limit acted due to material jamming	00:20:00	00:30:00	informed operation
11	CHP	scr-10 on cc-105	boom conveyor not working	MPD tripped. reset done	02:30:00	02:45:00	
12	CHP	R-1 on cc-33	boom conveyor not running	yard interlock cage stuck up due to stones	03:00:00	03:10:00	
13	CHP	scr-2 on cc-34	LT not working. over tension acted.	released. four times	23:45:00	02:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	STK-1 on cc-37	LT not working. PCRD gear box problem	drum arrested and informed to mechanical	03:40:00	03:50:00	
15	CHP	SCR-1 on cc-35	LT not working. PCRD over tension acted	Released and then ok	04:40:00	04:50:00	
16	WT	OP1	D4 olr tripped	Reset done	23:20:00	23:30:00	
17	WT	OP1	Drive 6 olr acted	Reset done	23:50:00	00:00:00	
18	IOSA	oc-17a to oc-19a	chute vibrator fallen	connections removed	00:15:00	00:30:00	