



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/08/2025

Area: OHP

Equipment	Job
tbs- on co-20	boom run signal latching is provided, needs to be reset in co-20 popup for healthiness. Indications have been provided for the same.