



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/11/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-30	Reported BW-1 not rotating	DMPR tripped on STL fault.Reset done	05:00:00	05:15:00	
2	OHP	CO-20	Reported ZSS acting	Mechanical problem.Motor rotating but gearbox no movement.	02:10:00	02:25:00	Informed to mechanical
3	OHP	TT-3 on CO-16	Reported LT not moving	CRD cable got cut.Joint done	04:30:00	05:40:00	Not a running complaint
4	CHP	Cc-51	Reported tripped	MPD tripped.Reset done	04:20:00	04:25:00	
5	CHP	CC-33 SCR-5	LT not taking place	Drive tripped.M-2 motor burnt.Removed from circuit and tested okay.	23:25:00	00:15:00	M-2 motor needs to be replaced
6	CHP	CC -105 SCR-10	Reported slew not taking place	Fault reset done and tested okay	23:50:00	00:00:00	
7	CHP	CC 125	Reported tripped	OLR acted.Reset done	05:05:00	05:10:00	
8	WT	OT-4	Reported initial not coming	Sensor adjusted and tested okay	23:55:00	00:15:00	
9	WT	OT-3	Reported not moving	Forward limit opened.Closed and tested okay	01:25:00	01:35:00	
10	WT	OP-3	Over travelled.collector pads fallen.	replaced and tested okay	04:15:00	04:30:00	
11	IOSA	OC-31A	Reported tripped	OLR acted due to stone stuck up at chute.Reset done	01:40:00	01:50:00	Informed to operation