



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/11/2025

Area: IOSA

Equipment	Job
OC-7B AND OC-27A	LIGHTING AND EXTENSION BOARD SUPPLY PROVIDED FOR BELT JOBS.
TBS- LDB	MAINTENANCE DONE ON LDB-1 AND 2 .
1-142LC-3	MAINTENANCE DONE ON INCOMER-1 FEEDER ACB IN PCC PANEL AND OUTGOING FEEDER TO OM-7 ACB.