



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/01/2026

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done(2times)	23:00:00	01:10:00	
2	OHP	WOBR on CO-29	Reported LT not taking place	M-3 tripped due to track jamming.Reset done(2 times)	23:10:00	02:10:00	Informed to operation
3	OHP	CO-34	Reported tripped	OLR acted.Reset done	00:00:00	00:05:00	
4	OHP	TBS on CO-24	LT not taking place	M-4 tripped.Made on	03:57:00	04:07:00	No delay
5	OHP	BRC on CO-31	CT not taking place	MCCB off.Made on	04:10:00	04:25:00	
6	OHP	CO-25	Reported tripped	OLR acted.Reset done	05:35:00	05:45:00	
7	CHP	CC-51	MPD acted	Fedding conveyor stopped.Reset done(2 times)	23:15:00	00:10:00	
8	CHP	Cc-131	Reported tripped	OLR acted.Reset done	00:45:00	00:50:00	
9	CHP	Cc-52	Reported tripped	OLR acted.Reset done(4 times)	23:22:00	01:40:00	
10	CHP	CC-31	Reported tripped	OLR acted.Reset done	22:10:00	22:30:00	
11	CHP	Cc-36 S-2	Lt not taking place	M-2 tripped.Made on	22:30:00	22:40:00	
12	CHP	Cc-32 SCR-5	LT not taking place	Drive tripped.Reset done	01:00:00	01:10:00	
13	WT	OT-1	Reported tripped	Drive-1 tripped on PGEF-1 fault.Reset done	03:35:00	03:40:00	