



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/04/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 34	tripped on olr	reset done	17:00:00 18:10:00	17:10:00 18:15:00	
2	OHP	co 16a	brs acted/reciver&trasmitter; alignment distrub	alignment done then ok	17:40:00	18:00:00	
3	CHP	cc 32 scr 5	It not taking place/pcrd cable over lap& tension acted	cable rewinding done	14:45:00	15:30:00	
4	CHP	cc 36 scr 1	It not taking place/drive tripped	reset done	15:00:00	15:15:00	
5	CHP	cc 34 scr 2	It not taking place/drive tripped	reset done	17:00:00	17:15:00	
6	CHP	cc 104 scr 9	slew not taking place/mptr tripped on earth fault	reset done	17:30:00	17:45:00	
7	CHP	cc 33 scr 4	It not taking place/mpcb tripped of m2 &m3;/due to track jamming.	mpcb s made on	18:00:00	18:10:00	
8	CHP	cc 114	brs bypass done for operation requirement	.	18:00:00	18:10:00	
9	CHP	cc 114	brs kept in ckt	.	21:50:00	22:00:00	
10	CHP	cc 132	tripped on olr	reset done	14:30:00	14:40:00	
11	CHP	cc 51a	tripped on olr due to over load	reset	15:15:00	15:25:00	
12	CHP	cc117	tripped on olr	reset	19:45:00	20:00:00	
13	WT	op 8	forward /reverse not taking place	D5 olr acted/reset done.	19:30:00	19:45:00	