



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 04/11/2025

Area: CHP

| Equipment         | Job   |
|-------------------|---|
| CC 28TT           | PPM was done  |
| LC 17             | Room cleaning done  |
| CC 41/42,43/44    | Ckt problems rectified and 4nos 70W fixtures provided                               |
| CC 34,37,SCR 2 ,7 | Running inspection was done   |
| SCR 4             | HT cable sleeve provided at old joint   |
| SCR 1             | LT motor fixed on the bed after mechanical job.New PCRD PENDULUM limit switch fixed |
| SCR 1             | HT coupler side cable terminated by DNW. Power charged                              |