



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/12/2025

Area: WT

Equipment	Job
OP 4	D2 motor placed and alignment done ,testing also done
OP 9	Creepers cleaning done @ col nos ,81 to 85
OP 4,6,8 and 9	After rake ,maintenance done