



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/06/2025

Shift: C

Incharge(s): V Balaji Naik,G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO66	BRS kept in ckt	as per operational request BRS kept in ckt	22:30:00	22:35:00	
2	OHP	WOBR on CO29	Yard conveyor inter lock cage struck up	new cage replaced then ok	05:00:00	05:30:00	
3	CHP	CC54	Over load acted 4 times due to over load	Reset done	01:40:00	01:45:00	02.35am to 02.40am:04.15am to 04.20am:04.55 am to 05.00am
4	CHP	CC51	ZSS acted due to over load	Reset done	02:00:00	02:10:00	
5	CHP	SCR3 on CC38	LT not working found VFD drive fault LVD drive trip	Reset done	22:50:00	23:00:00	
6	CHP	SCR2 on CC34	LT not working found PCRD cable over tension limit acted	Over tension limit released then ok	00:20:00	00:30:00	
7	CHP	CC35	BRS not getting reset	Sensors cleaned then ok	01:10:00	01:20:00	
8	CHP	CC131	Over load acted due to over load	reset done	05:45:00	05:50:00	
9	WT	OP5	not moving after 6 boxes tipping found D2 olr trip 2 times	Reset done again trip motor coil connection removed and declutch done	00:30:00	00:50:00	