



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/12/2025

Area: WT

| Equipment | Job |
|----------------|---|
| OP 4 | D2 tyre fixed by Mech. kept in circuit |
| E O T Crane(O) | Aux. Hoist rope changed by mechanical., gravity limit fixed and kept in circuit |
| CT 2 Area | 350W LED replaced at BAY and 1 no 400W S V fitting rectified |
| CC 3 Area | Lighting job done one no 200W LED installed |
| CP 1 to 4 | Inspection done@ parking zone |
| OP 2 to 8 | Inspection done@ parking zone |
| OP 1 and 7 | After rake maintenance done |