



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-30	REPORTED B/W-1 NOT RUNNING FOUND CONTROL MCB TRIPPED	MADE ON THAN OK	07:00:00	07:15:00	
2	OHP	CO-85	TRIPPED ON OLR (3TIMES)	RESET DONE	09:00:00 13:40:00 13:50:00	09:15:00 13:45:00 14:00:00	DUE TO MATERIAL JAMMING
3	OHP	CO-25	TRIPPED ON OLR	RESET DONE	10:00:00	10:15:00	
4	OHP	TBS ON CO-7A	REPORTED LT NOT TAKING PLACE FOUND SELECTOR SWITCH OFF POSITION	SELECTOR KEPT REMOTE THAN OK	10:00:00	10:15:00	
5	CHP	CC-52	FEEDING CONVEYOR MPD ACTED	RESET DONE	08:15:00	08:20:00	
6	CHP	CC-54	OLR ACTED	RESET DONE	12:35:00	12:40:00	
7	CHP	CC-51	MPD TRIP FEEDING CONVEYOR (3TIMES)	RESET DONE	08:05:00 08:15:00 12:35:00	08:10:00 08:20:00 12:40:00	
8	CHP	CC-31 SCR-4	LUFF DOWN LIMIT ACTED	BYPASSED OPERATION REQUIREMENT	07:00:00	07:05:00	
9	CHP	CC-33	OLR ACTED	RESET DONE	09:00:00	09:10:00	
10	CHP	CC-32 R-1	LUFF NOT WORKING FOUND MPCB TRIP	MADE ON THAN OK	10:05:00	10:15:00	
11	CHP	CC-33 SCR-5	LT NOT TAKING PLACE DRIVE TRIP (F7900) (2TIMES)	RESET DONE	10:05:00 12:10:00	10:15:00 12:15:00	
12	CHP	CC-125	OLR ACTED(2TIMES)	RESET DONE	10:10:00 12:05:00	10:15:00 12:10:00	