



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/10/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-6A	TRIPPED ON OLR (2TIMES)	RESET DONE	01:15:00 05:00:00	01:20:00 05:15:00	
2	OHP	CO-15A	TRIPPED ON OLR	RESET DONE	04:40:00	05:00:00	
3	OHP	CO-29	TRIPPED ON OLR (3TIMES)	RESET DONE	00:10:00 03:30:00 23:10:00	00:15:00 03:40:00 23:15:00	
4	OHP	WOBR ON CO-26	B/C TRIPPED ON OLR	RESET DONE	00:10:00	00:30:00	
5	OHP	CO-34	TRIPPED ON OLR	RESET DONE	02:10:00	02:20:00	
6	OHP	CO-11(C)	TRIPPED ON OLR	RESET DONE	04:40:00	05:00:00	
7	OHP	CO-5A	REPORTED STOPPING ON ZSS CHECKED AND FOUND MECHANICAL PROBLEM	INFORM TO MECHANICAL	23:00:00	23:30:00	
8	CHP	CC-54	TRIPPED ON OLR (15TIMES)	RESET DONE	23:00:00	04:30:00	
9	CHP	TIS ON CC-51	TRIPPED ON OLR	RESET DONE	03:40:00	03:50:00	
10	CHP	CC-52	TRIPPED ON OLR FEEDING CONVEYOR STOP	RESET DONE	01:35:00	01:40:00	
11	CHP	CC-33 SCR-5	REPORTED ALL DRIVES ARE NOT RUNNING FOUND PCRD CABLE OLD JOINT FLASH	SLIP RING SIDE CABLE OPEN THAN INFORM TO DNW	02:20:00	03:20:00	
12	CHP	CC-31	TRIPPED ON OLR	RESET DONE	03:50:00	04:00:00	
13	CHP	CC--38 SCR-6	REPOTED B/C NOT RUNNING FOUND OLR ACTED	RESET DONE	04:25:00	04:35:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/10/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-125	TRIPPED ON OLR	RESET DONE	05:15:00	05:20:00	
15	CHP	CC-203	TRIPPED ON OLR	RESET DONE	05:20:00	05:30:00	
16	WT	OT-1	REPORTED NOT MOVE FOUND DRIVE-1 TRIP (3TIMES) PGF-1 FAULT	RESET DONE	03:25:00	04:00:00	
17	IOSA	OC-37A TO CO-8A	Material request not coming to OCR-2	Checked and found high not available at relay contact at LC-3. Glass fuse blown at OM-1. Fuse replaced and tested okay	01:30:00 23:00:00	01:50:00 00:00:00	