



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/04/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CF 1	High to emergency stop missing	Loop given in CJB	01:30:00	01:50:00	
2	OHP	CO 36A	BRS to be bypassed	Bypassed at operation request	04:10:00	04:25:00	
3	OHP	CO 29	OLR acted	reset done	01:30:00 23:30:00	01:40:00 23:40:00	
4	CHP	CC 33 , SCR - 4	LT not working	Track jamming , informed to operation . Also M-3 and M-6 tripped .	23:45:00	00:30:00	Tripped 3 times due to jamming
5	CHP	CC 33 , SCR 4	BC stopping on ZSS	ZSS cage problem, adjusted and then ok	04:00:00	04:25:00	
6	CHP	CC 31 , S-3	BC not running	Overload acted. reset done	01:30:00	01:40:00	
7	CHP	CC 22	OLR acted	reset done . also found in local mode, kept in PLC	23:20:00	23:30:00	
8	CHP	CC 114 and CC 115	BRS to be bypassed	Bypassed as per operation request	23:45:00	00:00:00	In system
9	CHP	CC 33 , SCR 4	Reported BW not running	Checked, BW broken , informed to mechanical . For mechanical work , luffing lower limit bypassed and again kept in circuit.	00:30:00	01:30:00	
10	WT	cp 1	Pusher not moving forward	Forward limit acted. Reset done	01:30:00	02:10:00	
11	WT	CC 3	Belt drive not healthy	Pull chord acted by operation. Released, then ok	22:15:00	22:35:00	
12	WT	OP 7	Not moving	High missing in control desk . 110 V given temporarily	03:15:00	04:00:00	