



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-1A	OLR ACTED	RESET DONE	06:40:00	06:50:00	
2	OHP	BRC ON CO-30	B/W-2 OLR ACTED (STL FAULT)	RESET DONE	06:45:00	07:00:00	
3	OHP	CO-66	OLR ACTED	RESET DONE	07:30:00	07:40:00	
4	OHP	RSCO-10A (C/D)	TRIPPED ON OLR	RESET DONE	07:45:00	07:55:00	
5	OHP	WOBR-ON CO-25	REPORTED SLEW NOT WORKING FOUND DRIVE TRIP	RESET DONE	09:30:00	09:45:00	
6	OHP	BRC ON CO-8A	REPORTED LT NOT TAKING PLACE ACB TRIP	ACB MADE ON THAN OK	10:45:00	10:55:00	
7	OHP	CR-1	TRIPPED ON OVER CURRENT FAULT	RESET DONE	11:30:00	11:40:00	
8	CHP	CC-131	OLR ACTED	RESET DONE	12:20:00	12:30:00	
9	CHP	CC-54	TRIPPED ON OLR (6TIMES)	RESET DONE	11:20:00	13:00:00	
10	CHP	CC-117	OLR ACTED	RESET DONE	08:00:00	08:10:00	
11	CHP	CC-51	MPD TRIP FEEDING CONVEYOR (2TIMES)	RESET DONE	10:20:00 11:20:00	10:25:00 11:25:00	
12	CHP	CC-51	OLR ACTED	RESET DONE	11:55:00	12:00:00	
13	CHP	CC-45	OLR TRIP	RESET DONE	06:20:00 08:40:00	06:30:00 08:45:00	
14	CHP	CC-47	DRIVE TRIP	RESET DONE	07:40:00	07:50:00	
15	CHP	CC-107	OLR ACTED	RESET DONE	09:05:00	09:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC-31 SCR-4	REPORTED PCRD CABLE FELL DOWN CHECKED GUIDE PROBLEM INFORMED TO MECHANICAL	AFTER RECTIFIED GUIDE PROBLEM PCRD CABLE PROPERLY WINDED THAN OK	09:30:00	09:45:00	
17	CHP	CC-37 SCR-7	B/W NOT RUNNING FOUND SELECTOR SWITCH PROBLEM	SELECTOR SWITCH REPLACED THAN OK	10:00:00	10:30:00	
18	WT	CO-3	OLR ACTED (2TIMES)	RESET DONE	06:20:00 08:10:00	06:30:00 08:20:00	
19	WT	CC-1 (C/D)	TRIPPED ON OLR	RESET DONE	11:20:00	11:30:00	