



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/07/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 3B	Pull chord acted	Bypassed and after pull chord reset bypass removed	17:00:00	17:45:00	
2	OHP	CO 87	OLR acted	reset done	17:50:00	18:10:00	
3	OHP	CO 29	OLR acted	reset done	17:55:00	18:05:00	
4	OHP	CR 3	Tripped	reset done	20:45:00	20:55:00	
5	OHP	VF 8A	OLR acted	reset done	20:45:00	20:55:00	
6	OHP	TBS on CO 5A	No drive working	Control was in Off condition in operator cabin , made on	20:50:00	21:05:00	
7	CHP	CC 47	BRS acting due to dust	Checked, informed to operation	15:35:00	15:50:00	
8	CHP	CC 38	BRS acted	No electrical problem	15:45:00	15:50:00	
9	CHP	CC 112 , SCR 8	BC not running	fault reset done	17:00:00	17:20:00	
10	CHP	CC 34	Not healthy	Motor protection relay malfunctioning . Bypassed in TB	18:00:00	18:30:00	
11	CHP	CC 40 , SCR 6	LT not working	MPCB 2 tripped , made on	20:05:00	20:20:00	
12	CHP	CC 29 TT	Not moving	MPCB tripped , made on	16:00:00	16:15:00	
13	CHP	JH 3	Hoist problem	Up contactor NC block loose , tightened then ok	18:00:00	18:30:00	
14	CHP	CC 54	Tripped on overload	reset done	16:00:00	16:10:00	
15	CHP	CC 53	Tripped on overload ( 3 times) due to material jamming	reset done and informed to operation	19:00:00	19:45:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/07/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 131	Tripped on overload ( 2 times)	reset done	20:00:00	20:25:00	
17	CHP	CC 51	Stopped on zero speed ( 2 times) due to material on belt	Informed to operation	17:00:00	17:45:00	