



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/10/2025

Area: IOSA

Equipment	Job
LIGHTING	TWO 200W LED LIGHT FITTINGS PROVIDED FOCUSING 1B BED
OC-11A	PPM DONE ON RMU UNIT AT OC-11A
OC-19A and 21A	SINGLE PHASE SOCKETS AND WELDING POWER SUPPLY UNITS CHECKED AND RECTIFIED.
TBS	PCRD PENDULUM CHAIN GUIDER PROBLEM RECTIFIED. CABLE LOOP WINDING DONE AND TRIAL RUN TAKEN.
WOBR-FLS	LUFFING NOT TAKING PLACE. CHECKED ANS FOUND PROPORTIONAL CARD SOLENOID CONTACT PROBLEM. CLEANED CONTACT, TESTED , FOUND OK.
OJH-4C	PPM DONE ON ELECTRICAL HOIST PANEL.