



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/05/2025

Shift: C

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC54	tripped due to over load	informed to operation to remove over load and reset done	01:05:00 02:35:00 03:30:00 04:50:00 23:35:00	01:10:00 02:40:00 03:35:00 04:55:00 23:40:00	
2	OHP	CO4a	BRS bypassed in module	Malfunctioning	00:00:00	00:10:00	
3	OHP	BRC on CO32	Bw not running due to over load	Reset done	23:30:00	23:45:00	
4	OHP	Stacker on CO5a	LT not stopping found push button struck in operator cabin	push button released then ok	02:10:00	02:30:00	
5	OHP	CO25	Over load	Reset done	02:50:00	03:05:00	
6	OHP	CO26	OLR acted( 2 times)	Reset done	01:25:00 03:50:00	01:35:00 04:00:00	
7	OHP	BRC on CO28	BW1 not working found stone struck	Informed to mechanical	05:50:00	06:10:00	
8	CHP	SCR7 on CC39	LT not working found E stop not released	E stop released then ok	22:34:00	22:45:00	Not an electrical delay
9	CHP	SCR6 on CC40	Boom conveyor not running found motor over load MPD trip	Reset done and informed to operation for over load remove	02:30:00 03:20:00 04:30:00 04:40:00	02:40:00 03:40:00 04:35:00 04:45:00	
10	CHP	CC35	BRS bypassed as per operation request	bypass done in i/o rake and removed as per operation request	03:50:00	03:55:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/05/2025

Incharge(s): V Balaji Naik

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	SCR6 on CC40	LT not working drive fault code F30003	Drive reset done then ok	05:35:00	05:40:00	