



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/10/2025

Area: WT

Equipment	Job
cp-3	panel and motor side ppm done
op-6	Trolley line checking done found top section bus bar misaligned at col no:31 rectified it then ok.