



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/02/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 4 CD	OLR ACTED	RESET	22:30:00	22:35:00	
2	OHP	CO 34	OLR ACTED	RESET	02:00:00 23:30:00	02:05:00 23:35:00	
3	OHP	CO 26	OLR ACTED	RESET	01:45:00 04:30:00	01:55:00 04:40:00	
4	OHP	WBR ON CO 25 LT	PCRD O/T ACTED	RESET	02:00:00	02:15:00	
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	02:00:00	05:00:00	3 TIMES
6	CHP	SCR 2 ON CC 40	AFTER DNW CLEARANCE	HT CHARGED CHECKED AND GIVEN CLEARANCE	22:00:00	01:20:00	
7	CHP	CC 219 RED	C/S ACTED	RESET	02:00:00	02:15:00	
8	CHP	SCR7 ON CC 104	PCRD O/T ACTED	RESET	05:30:00	05:40:00	
9	WT	OT2	DRIVE 2 TRIPPED ON PGF1 FAULT	RESET	05:35:00	05:40:00	