



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/04/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT3 CHUTE VIBRATOR	R PHASE GOT CUT IN MOTOR TB	CONNECTED PROPERLY	20:30:00	20:40:00	
2	OHP	TT3 21 POSITION	FEMALE PLUG DAMAGED	REPLACED THEN OK	18:30:00	18:50:00	
3	OHP	co 11a	brs acted	reset done	20:00:00	20:10:00	
4	OHP	BRC ON CO 31 B/C	OLR ACTED DUE TO JAMMING	RESET	15:45:00	16:00:00	
5	OHP	BRC ON CO 34 CT & LT	ACB TRIPPED	MADE IT ON	18:15:00	18:30:00	
6	OHP	WBR ON CO 6A	YARD INTERLOCK SIGNAL LAMP	REPLACED	14:30:00	14:50:00	
7	OHP	CO 68	I O ACTED	RESET	16:15:00	16:30:00	
8	OHP	co 11 c/d	tripped on olr	reset done	21:40:00	21:50:00	
9	OHP	CO 29	tripped on olr	reset done	19:45:00	19:50:00	
10	CHP	SCR6 on CC 40 LUFF	OIL LEACKAGE	INFORMED TO MECH	18:30:00	18:50:00	
11	CHP	CC 107	OLR ACTED	RESET	21:15:00	21:20:00	
12	WT	OT2	DRIVE 2 TRIPPED ON PGF1	RESET	21:10:00	21:15:00	
13	IOSA	TBS	RIGHT B/C OLR ACTED	RESET	15:10:00	15:25:00	