



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Shift: B

Incharge(s): M Kailash

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co-29	Overload acted	Reset done	20:10:00	20:20:00	.
2	OHP	TBS on CO-7A	Right luffing up not working	found limit switch tied with rope. limit switch made free and given clearance	17:20:00	17:30:00	.
3	OHP	co-19	Reported not running in Local mode	Found EM-Stop NC block contact problem. Rectified	17:05:00	17:15:00	.
4	OHP	VF-10	Motor not running. Found cable rubbing at motor TB gland	Proper packing and taping provided and tested ok	21:15:00	21:40:00	
5	OHP	VF-9A	Chute vibrator motor not running. Found motor Y phase got cut inside the motor TB.	Cable re jointing done and made ok	21:50:00	22:00:00	
6	CHP	cc-110	zss complaint	checked module and probe and found ok.	19:30:00	19:45:00	.
7	CHP	cc-29	overload acted	Reset done	17:30:00	17:40:00	.
8	CHP	CC-51	MPD tripped on overload to stop feeding conveyor (6 times)	Reset done	15:35:00	17:15:00	.
9	CHP	CC-114	Overload tripped	Reset done	17:50:00	18:00:00	
10	CHP	CC-131	Overload trip	Reset done	19:35:00 21:10:00	19:40:00 21:15:00	
11	CHP	CC-54	Overload acted	Reset done	20:50:00 21:00:00	20:55:00 21:05:00	
12	CHP	CC-114	ZSS acted.	Checked and found belt snapped. Informed to operation	18:15:00	18:20:00	
13	CHP	SCR-4	Luffing not working. Found oil level low.	Informed to mechanical. After oil filling, checked OK	15:05:00	15:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/10/2025

Incharge(s): M Kailash

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	AF-4	Drive tripping on un balance fault.	Motor decoupled and checked. Still drive is tripping. Motor meggered and found winding fault	19:00:00	22:30:00	Motor changing is under progress
15	WT	SCO-1A	Carriage drive not moving. Overload acted	Reset done	16:00:00	16:10:00	
16	WT	OT-3	Not rotating. Found FWD limit not closing properly	Made ok	17:10:00	17:20:00	