



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/08/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 31	CT speed change request from 550 to 600 rpm	changed	04:00:00	04:15:00	
2	OHP	CO 25 WOBR	BW not rotating bcz of idler stuck in BW	BW direction change on operation request , again normalised	02:00:00	02:15:00	
3	OHP	WOBR on CO 29	LT M4 overload acted	reset done	02:55:00	03:20:00	
4	OHP	WOBR on CO 29	BC overload acted	reset done	00:20:00	00:40:00	
5	OHP	TBS on CO 20	Chute sensor not resetting	bypassed in module	23:30:00	23:50:00	
6	CHP	CC 51	Tripped (3 times)	reset done	22:45:00	03:50:00	
7	CHP	CC 51	MPD tripped (2 times)	reset done	02:55:00	04:50:00	feeding conveyor stopped
8	CHP	CC 131	Tripped on overload	reset done	05:15:00	05:25:00	
9	CHP	CC 105 , SCR 7	BC not running in stacking mode	operator fault , selector switch is in rec mode. Changed to stacking mode, then ok	22:15:00	22:30:00	
10	CHP	CC 105 , SCR 7	LT not working	Drive tripped , reset done	00:00:00	00:20:00	
11	CHP	CC 125	OLR acted	reset done	04:00:00	04:10:00	
12	CHP	CC 35, SCR 1	BW not running due to OLR acted	reset done	04:20:00	04:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	CO 4	Belt drive tripped on overload due to material jamming	reset done	00:45:00 04:20:00	00:50:00 04:25:00	