



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/06/2025

Area: OHP

Equipment	Job
RSCO-10A	Chute vibrator not working.To be replaced
CO-11,12,13	Chute vibrators maintenance done
1-141LC-4	All Drives PPM done
LOCP-2,LOSP-2	Electrical side inspection done
WOBR on CO-6A	LT M3 checking done and kept in line and tested okay
BRC-2 ON CO-31	LT M5 motor checking done and kept in line and tested okay
TBS on CO-24	Transformer earthing provided
TBS on CO-21	Chute vibrator termination and cable laying done.Power to be provided from MCC
BRC on CO-8A	BW-2 ZSS rectified and kept in line
BRC-4 on CO-34	BW ZSS inspection done
Coupler gas cut	Preparation done
Transfer car	PPM done