



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/10/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------------------|---|--|----------------------|----------------------|---------|
| 1 | OHP | CO-29 | TRIPPED ON OLR | RESET DONE | 09:00:00 | 09:10:00 | |
| 2 | OHP | RSCO-10A (BELT DRIVE) | TRIPPED ON OLR | RESET DONE | 09:10:00 | 09:20:00 | |
| 3 | OHP | CO-85 | TRIPPED ON OLR | RESET DONE | 12:15:00 | 12:30:00 | |
| 4 | OHP | BRC ON CO-32 | REPORTED LT NOT TAKING PLACE CHECKED AND FOUND BREAK PROBLEM | THRUSTER BREAK FREE IT AND CONNECTION REMOVED | 12:00:00 | 12:15:00 | |
| 5 | CHP | CC-54 | TRIPPED ON OLR (5TIMES) | RESET DONE | 09:00:00 | 10:00:00 | |
| 6 | CHP | CC-38 SCR-6 | LT NOT TAKING PLACE DRIVE TRIP | DRIVE RESET DONE | 09:00:00 | 09:15:00 | |
| 7 | CHP | CC-36 S-2 | REPORTED LT NOT TAKING PLACE CHECKED AND FOUND PCRD GEAR BOX PROBLEM INFORMED TO MECHANICAL | AFTER FIXING GEAR BOX PCRD CABLE PROPER LAYING WAS DONE THAN OK | 08:30:00 12:00:00 | 08:40:00 12:40:00 | |