



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/10/2025

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	Tt3 c/s indication not coming	i Phase loose in power JB near middle of conveyor and control supply not healthy	Properly tightened then ok	15:45:00	16:30:00	
2	OHP	RSCO 10a CD	Olr acted	Reset	18:05:00	18:20:00	
3	OHP	CO 26 lt	Drive tripped due to Track jamming	Reset	21:30:00	21:45:00	
4	OHP	Brc on co 33m	Lt pcrd o/t acted	Released	20:25:00	20:45:00	
5	OHP	Wbr on co 25	Slew drive tripped	Made it on	21:00:00	21:15:00	
6	OHP	Co 35	Olr acted	Reset	21:05:00	21:10:00	
7	OHP	CO 10 A	olr acted	reset	15:45:00	15:55:00	
8	CHP	scr 3 on cc 40	Lt m5 tripped due to track jamming	Reset and informed to oprn	15:45:00	16:00:00	
9	CHP	R1 on cc 32 b/c	Interlock cage stuck due to coal piece	Piece removed then ok	20:55:00 21:20:00	21:05:00 21:30:00	
10	CHP	CC 131	Olr acted	Reset	15:30:00 16:40:00 19:20:00	15:35:00 16:45:00 19:25:00	
11	CHP	cc 54	Olr acted	Reset	16:00:00	19:45:00	7 times due to tail end jamming later cleaned