



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OLR (3 TIMES)	RESET DONE	00:30:00 03:00:00 22:50:00	00:40:00 03:05:00 23:00:00	
2	OHP	WBR ON CO-29	BC TRIPPED ON OLR	RESET DONE	04:00:00	04:15:00	
3	OHP	CO-111	TRIPPED ON OLR	RESET DONE	05:45:00	05:50:00	
4	CHP	CC-31 SCR-4	LT NOT WORKING PCRD OVER TENSION ACTED	RELEASED	22:30:00	22:40:00	
5	CHP	CC-32 SCR-5	BC MPD ACTED ON OL	RESET DONE	23:25:00	23:35:00	
6	CHP	CC-202 AND CC 203	TRIPPED ON OLR	RESET DONE	23:50:00	00:05:00	
7	CHP	CC-54	TRIPPED ON OLR	RESET DONE	04:05:00	04:10:00	
8	CHP	CC-131	TRIPPED ON OLR	RESET DONE	00:30:00	00:35:00	
9	CHP	CC-117	TRIPPED ON OLR	RESET DONE	23:03:00	23:18:00	
10	CHP	CC-114	TRIPPED ON OLR	RESET DONE	05:05:00	05:15:00	
11	CHP	CC -51	TRIPPED ON OLR	RESET DONE	05:05:00 05:20:00	05:10:00 05:25:00	
12	CHP	CC-19	TRIPPED ON OLR 2 TIMES	RESET DONE	23:15:00	23:25:00	
13	CHP	CC-39 SCR-6	BC TRIPPED ON OLR	RESET DONE	05:30:00	05:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-54	TRIPPED ON OLR	RESET DONE	05:45:00	05:55:00	
15	WT	CT-2	INITIAL NOT CAME .. REV LIMIT STUCK	RELEASED	02:30:00	02:40:00	