



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/08/2025

Area: OHP

Equipment	Job
co-77 and co-84 gallery	lighting has been improved,
brc-2	shifted for co-30 to co-31 ; M1 motor MPCB fixed and taken into circuit.
brc-3	shifted from co-31 to co-32
TT-1,2,3,4	position sensors have been checked, TT-1 and TT-2 on co-8a sensors not working, Position can be bypassed as per need.