



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on co 28	LT not working,PCRD OT acted	released OT	16:20:00	16:30:00	mech guide problem
2	OHP	CO 34	OLR acted	reset	20:10:00	20:15:00	
3	OHP	CO 12A	BRS acted ,not able to reset	sensor cleaned and adjusted,given clearance	16:25:00	16:35:00	
4	OHP	TT3	control mcb tripped	made it on	20:30:00	20:45:00	
5	CHP	CC 104 SCR 7	LT not working,drive tripped in OVI	reset	14:10:00	14:15:00	
6	CHP	CC 51	MPD acted	reset	16:05:00	16:10:00	7 times
7	CHP	CC 103 FG	mpcb tripped	made it on	14:35:00	14:45:00	