



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/09/2025

Incharge(s): V Balaji Naik, Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 10A(b)	tripped due to overload	reset	04:55:00	05:05:00	
2	CHP	CC 39 scr3	b/w not running, signal issue	PLC power recycle and LT done	22:22:00	22:32:00	
3	CHP	CC 32 scr 5	LT not working, OT acted	OT released	22:40:00	23:00:00	
4	CHP	CC 35 SCR 7	LT not working, OT acted	OT released	01:30:00	01:40:00	
5	CHP	CC 34 SCR 2	LT not working, OT acted	OT released	04:58:00	05:12:00	
6	CHP	CC 104 SCR 9	LT not working, OT acted	OT released	23:00:00	23:15:00	
7	CHP	CC 32 SCR 5	LT not working, drive trips in overload	reset	02:30:00	02:40:00	