



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/01/2026

Incharge(s): Amit Roy

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|-------------------------------------|--|----------|----------|---------|
| 1 | OHP | WOBR on CO-29 | Reported no operations taking place | MCB tripped in PLC panel.Made on | 22:30:00 | 22:40:00 | |
| 2 | OHP | WOBR on CO-29 | Reported no operations taking place | Down limit acted.Boom lifted and tested okay | 03:40:00 | 03:50:00 | |
| 3 | OHP | WOBR on CO-29 | Reported LT not taking place | PCRD tension acted.Released and tested okay | 04:00:00 | 04:10:00 | |
| 4 | OHP | CO-25 | Reported tripped | OLR acted.Reset done | 00:30:00 | 00:40:00 | |
| 5 | CHP | CC-28 | Reported tripped | OLR acted.Reset done(2 times) | 23:15:00 | 02:15:00 | |
| 6 | CHP | CC-29 | Reported tripped | OLR acted.Reset done(2 times) | 04:10:00 | 05:25:00 | |
| 7 | CHP | CC-125 | Reported tripped | OLR acted.Reset done | 23:55:00 | 00:05:00 | |
| 8 | CHP | CC-54 | Reported tripped | OLR acted.Reset done(3 times) | 00:15:00 | 05:30:00 | |
| 9 | CHP | CC-51 | MPD tripped | Reset done | 05:00:00 | 05:10:00 | |
| 10 | CHP | CC-131 | Reported tripped | OLR acted.Reset done(3 times) | 23:30:00 | 03:30:00 | |
| 11 | CHP | CC-51A | ZSS acting | Cage stuck.Cage replaced and tested okay | 00:10:00 | 00:40:00 | |