



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/07/2025

Area: OHP

Equipment	Job
BRC-5 on CO-33M	PPM done
wobr-1	io rack panel sifted into mcc and welded in position.
co-2a	motor and panel side ppm is done
co-111,112,113	estops replaced
daybins-1	illumination improved along each conveyor levels.
vf-21 and vf-23	Feed rate increased by 10% for each