



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/12/2025

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------|------------------------------------|------------------|----------|----------|---------|
| 1 | OHP | OT 3 | DRIVE 1 TRIPPED | RESET | 05:20:00 | 05:25:00 | |
| 2 | OHP | CO 67 | OLR ACTED | RESET | 02:35:00 | 02:45:00 | |
| 3 | OHP | CO 26 | OLR ACTED | RESET | 02:35:00 | 02:45:00 | |
| 4 | CHP | SCR 6 ON C 38 | B/C MOTOR | REPLACEMENT DONE | 22:00:00 | 04:00:00 | |
| 5 | CHP | CC 48 | MECH BRS ACTED DUE TO BELT PIECE | CUT IT THEN OK | 23:30:00 | 23:40:00 | |
| 6 | CHP | SCR 1 ON CC 34 | LUFF LIMIT ACTD | RELEASD | 01:20:00 | 01:30:00 | |
| 7 | CHP | SCR 1 ON CC 34 | B/W OLR ACTED , SLEW DRIVE TRIPPED | RESET | 04:30:00 | 04:45:00 | |
| 8 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 23:00:00 | 06:00:00 | 8 TIMES |
| 9 | CHP | CC 54 | OLR ACTED | RESET | 05:50:00 | 05:55:00 | |