



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/11/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------|---|------------------------------|----------------------|----------------------|--------------------------------------|
| 1 | OHP | CO-16 | TRIPPED ON OLR(2TIMES) | RESET DONE | 07:40:00 08:20:00 | 07:50:00 08:30:00 | |
| 2 | OHP | CO-36 | REPORTED BRS NOT RESET | BYPASSED AND CLEARANCE GIVEN | 06:45:00 | 07:00:00 | SENSORS ADJUSTED AND KEPT IN CIRCUIT |
| 3 | CHP | TT ON CC-26 | REPORTED LT NOT WORKING FOUND MPCB TRIP | MADE ON | 07:15:00 | 07:30:00 | |
| 4 | CHP | CC-54 | TRIPPED ON OLR (12 TIMES) | RESET DONE | 06:50:00 | 13:30:00 | |
| 5 | CHP | CC-51 | FEEDING CONVEYOR MPD TRIP | RESET DONE | 08:30:00 | 08:35:00 | |