



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 18/09/2025

Incharge(s): Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	C0 12	Tripped , carriage drive MPCB acted	reset done	01:55:00	02:10:00	
2	OHP	BF 1A	tripped due to OL, Y phase lug damaged at motor cable side	reset,Y phase lug relugged	23:20:00	00:30:00	
3	OHP	CO 26	OLR acted	reset	01:30:00	01:40:00	
4	CHP	CC 51	MPD tripped	reset	22:30:00	06:00:00	
5	CHP	CC 32	MPR tripped	reset	22:15:00	22:25:00	
6	CHP	CC 31, SCR 4	LT not running	track jamming , informed operation	23:20:00	23:40:00	
7	CHP	CC 39 , SCR 3	LT not working , jamming	informed to operation	03:30:00	03:50:00	
8	CHP	CC 39	Tripped on overload	reset	05:00:00	05:10:00	
9	WT	EOT Crane ore	main power contactor outgoing B phase lug damaged	replaced and climping done	22:15:00	22:30:00	